

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
CITI-01	9/23/2025 05:03	10/21/2025 21:10	70384538001	Lead	<1.0	5	ug/L
CITI-02	9/23/2025 05:04	10/21/2025 21:12	70384538002	Lead	<1.0	5	ug/L
CITI-03	9/23/2025 05:07	10/21/2025 21:13	70384538003	Lead	<1.0	5	ug/L
CITI-04	9/23/2025 05:08	10/21/2025 21:15	70384538004	Lead	<1.0	5	ug/L
CITI-05	9/23/2025 05:08	10/21/2025 21:16	70384538005	Lead	<1.0	5	ug/L
CITI-06	9/23/2025 05:09	10/21/2025 21:18	70384538006	Lead	<1.0	5	ug/L
CITI-07	9/23/2025 05:10	10/21/2025 21:22	70384538007	Lead	<1.0	5	ug/L
CITI-08	9/23/2025 05:51	10/21/2025 21:24	70384538008	Lead	<1.0	5	ug/L
CITI-09	9/23/2025 05:52	10/21/2025 21:25	70384538009	Lead	<1.0	5	ug/L
CITI-10	9/23/2025 05:53	10/21/2025 21:27	70384538010	Lead	1.4	5	ug/L
CITI-11	9/23/2025 06:02	10/21/2025 21:28	70384538011	Lead	<1.0	5	ug/L
CITI-12	9/23/2025 06:04	10/21/2025 21:30	70384538012	Lead	<1.0	5	ug/L
CITI-13	9/23/2025 06:05	10/21/2025 21:31	70384538013	Lead	<1.0	5	ug/L
CITI-14	9/23/2025 06:38	10/21/2025 21:32	70384538014	Lead	<1.0	5	ug/L
CITI-15	9/23/2025 06:39	10/21/2025 21:34	70384538015	Lead	<1.0	5	ug/L
CITI-16	9/23/2025 06:39	10/21/2025 21:35	70384538016	Lead	<1.0	5	ug/L
CITI-17	9/23/2025 06:40	10/21/2025 21:40	70384538017	Lead	1.3	5	ug/L
CITI-18	9/23/2025 06:42	10/21/2025 21:41	70384538018	Lead	<1.0	5	ug/L
CITI-19	9/23/2025 06:43	10/21/2025 21:46	70384538019	Lead	1.9	5	ug/L
CITI-20	9/23/2025 06:54	10/21/2025 21:50	70384538020	Lead	4.2	5	ug/L
CITI-21	9/23/2025 06:55	10/21/2025 21:57	70384538021	Lead	<1.0	5	ug/L
CITI-22	9/23/2025 06:57	10/21/2025 21:59	70384538022	Lead	4.6	5	ug/L
CITI-23	9/23/2025 06:58	10/21/2025 22:00	70384538023	Lead	2.5	5	ug/L
CITI-24	9/23/2025 06:59	10/21/2025 22:02	70384538024	Lead	9.6	5	ug/L
CITI-25	9/23/2025 07:01	10/21/2025 22:03	70384538025	Lead	3.8	5	ug/L
CITI-26	9/23/2025 07:03	10/21/2025 22:04	70384538026	Lead	10.7	5	ug/L
CITI-27	9/23/2025 07:10	10/21/2025 22:06	70384538027	Lead	<1.0	5	ug/L
CITI-28	9/23/2025 07:10	10/21/2025 22:07	70384538028	Lead	2.2	5	ug/L
CITI-29	9/23/2025 07:11	10/21/2025 22:09	70384538029	Lead	<1.0	5	ug/L
CITI-30	9/23/2025 07:12	10/21/2025 22:10	70384538030	Lead	<1.0	5	ug/L
CITI-31	9/23/2025 07:12	10/21/2025 22:15	70384538031	Lead	<1.0	5	ug/L
CITI-32	9/23/2025 07:29	10/21/2025 22:16	70384538032	Lead	1.9	5	ug/L
CITI-33	9/23/2025 07:29	10/21/2025 22:18	70384538033	Lead	1.9	5	ug/L
CITI-34	9/23/2025 07:30	10/21/2025 22:19	70384538034	Lead	2.0	5	ug/L
CITI-35	9/23/2025 07:30	10/21/2025 22:21	70384538035	Lead	3.9	5	ug/L
CITI-36	9/23/2025 07:32	10/21/2025 22:22	70384538036	Lead	1.8	5	ug/L
CITI-37	9/23/2025 07:32	10/21/2025 22:24	70384538037	Lead	4.5	5	ug/L
CITI-38	9/23/2025 07:33	10/21/2025 22:25	70384538038	Lead	6.4	5	ug/L
CITI-39	9/23/2025 07:33	10/21/2025 22:32	70384538039	Lead	1.8	5	ug/L
CITI-40	9/23/2025 07:35	10/21/2025 22:37	70384538040	Lead	1.8	5	ug/L
CITI-41	9/23/2025 07:36	10/21/2025 22:41	70384538041	Lead	1.8	5	ug/L
CITI-42	9/23/2025 07:38	10/21/2025 22:42	70384538042	Lead	1.6	5	ug/L
CITI-43	9/23/2025 07:44	10/21/2025 22:44	70384538043	Lead	1.3	5	ug/L
CITI-44	9/23/2025 08:02	10/21/2025 22:45	70384538044	Lead	<1.0	5	ug/L
CITI-45	9/23/2025 08:02	10/21/2025 22:50	70384538045	Lead	<1.0	5	ug/L
CITI-46	9/23/2025 08:04	10/21/2025 22:51	70384538046	Lead	<1.0	5	ug/L
CITI-47	9/23/2025 08:04	10/21/2025 22:52	70384538047	Lead	<1.0	5	ug/L
CITI-48	9/23/2025 08:08	10/21/2025 22:54	70384538048	Lead	<1.0	5	ug/L

CITI-49	9/23/2025 08:09	10/21/2025 22:55	70384538049	Lead	<1.0	5	ug/L
CITI-50	9/23/2025 08:09	10/21/2025 22:57	70384538050	Lead	<1.0	5	ug/L
CITI-50A	9/24/2025 07:13	10/21/2025 22:58	70384538051	Lead	2.4	5	ug/L
CITI-51	9/24/2025 07:17	10/21/2025 23:00	70384538052	Lead	<1.0	5	ug/L
CITI-52	9/24/2025 07:17	10/21/2025 23:01	70384538053	Lead	<1.0	5	ug/L
CITI-53	9/24/2025 07:18	10/21/2025 23:03	70384538054	Lead	<1.0	5	ug/L
CITI-54	9/24/2025 07:19	10/22/2025 10:58	70384538055	Lead	<1.0	5	ug/L
CITI-55	9/24/2025 07:20	10/22/2025 10:59	70384538056	Lead	<1.0	5	ug/L
CITI-56	9/24/2025 07:22	10/22/2025 11:01	70384538057	Lead	<1.0	5	ug/L
CITI-57	9/24/2025 07:22	10/22/2025 11:05	70384538058	Lead	<1.0	5	ug/L
CITI-58	9/24/2025 07:23	10/22/2025 11:10	70384538059	Lead	<1.0	5	ug/L
CITI-59	9/24/2025 07:24	10/22/2025 11:14	70384538060	Lead	<1.0	5	ug/L
CITI-60	9/24/2025 07:24	10/22/2025 11:18	70384538061	Lead	<1.0	5	ug/L
CITI-61	9/24/2025 07:25	10/22/2025 11:22	70384538062	Lead	<1.0	5	ug/L
CITI-62	9/24/2025 07:27	10/22/2025 11:24	70384538063	Lead	16.8	5	ug/L
CITI-63	9/24/2025 07:27	10/22/2025 11:25	70384538064	Lead	7.9	5	ug/L
CITI-64	9/24/2025 07:29	10/22/2025 11:27	70384538065	Lead	1.5	5	ug/L
CITI-65	9/24/2025 07:29	10/22/2025 11:28	70384538066	Lead	1.7	5	ug/L
CITI-66	9/24/2025 07:32	10/22/2025 11:30	70384538067	Lead	1.4	5	ug/L
CITI-67	9/24/2025 07:33	10/22/2025 11:31	70384538068	Lead	1.3	5	ug/L
CITI-68	9/24/2025 07:33	10/22/2025 11:33	70384538069	Lead	13.2	5	ug/L
CITI-69	9/24/2025 07:35	10/22/2025 11:34	70384538070	Lead	3.5	5	ug/L
CITI-70	9/24/2025 07:36	10/22/2025 11:35	70384538071	Lead	1.4	5	ug/L
CITI-71	9/24/2025 07:38	10/22/2025 11:40	70384538072	Lead	14.2	5	ug/L
CITI-72	9/24/2025 07:48	10/22/2025 11:41	70384538073	Lead	14.1	5	ug/L
CITI-73	9/24/2025 07:48	10/22/2025 11:43	70384538074	Lead	1.5	5	ug/L
CITI-74	9/24/2025 07:51	10/22/2025 11:44	70384538075	Lead	<1.0	5	ug/L
CITI-75	9/24/2025 07:51	10/22/2025 11:46	70384538076	Lead	<1.0	5	ug/L
CITI-76	9/24/2025 07:52	10/22/2025 11:47	70384538077	Lead	<1.0	5	ug/L
CITI-77	9/24/2025 07:53	10/22/2025 11:48	70384538078	Lead	<1.0	5	ug/L
CITI-78	9/24/2025 07:54	10/22/2025 11:53	70384538079	Lead	2.4	5	ug/L
CITI-79	9/24/2025 07:55	10/22/2025 12:00	70384538080	Lead	2.9	5	ug/L
CITI-80	9/24/2025 07:58	10/22/2025 12:02	70384538081	Lead	1.8	5	ug/L
CITI-81	9/24/2025 07:59	10/22/2025 12:03	70384538082	Lead	3.2	5	ug/L
CITI-82	9/24/2025 08:00	10/22/2025 12:04	70384538083	Lead	3.0	5	ug/L
CITI-83	9/24/2025 08:01	10/22/2025 12:06	70384538084	Lead	2.3	5	ug/L
CITI-84	9/24/2025 08:02	10/22/2025 00:17	70384538085	Lead	2.0	5	ug/L
CITI-85	9/24/2025 08:03	10/22/2025 00:18	70384538086	Lead	2.2	5	ug/L
CITI-86	9/24/2025 08:05	10/22/2025 00:19	70384538087	Lead	10.2	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb

Sample ID Sample Location Outlet Description Notes

Citi South

CITI-01	Rm 102	Sink	
CITI-02	Rm 102	Sprayer	
CITI-03	Rm 109	Sink L	
CITI-04	Rm 109	Sink R	
CITI-05	Rm 110	Sink L	
CITI-06	Rm 110	Sink R	
CITI-07	Rm 111	Water Fountain	

Citi on Main

CITI-08	2nd Floor Kitchen	Sink	
CITI-09	2nd Floor Bathroom	Sink	
CITI-10	1st Floor Bathroom	Sink	

CARE

CITI-11	Kitchen Sink	Sink	
CITI-12	Bathroom L	Sink	
CITI-13	Bathroom R	Sink	

Cayuga Community College

CITI-14		Drinking Fountain	
CITI-15		Bottle Fill	
CITI-16	Front Mens Bathroom	Sink	
CITI-17	Front Womens Bathroom	Sink	
CITI-18	Inclusive BR L	Sink	
CITI-19	Inclusive BR R	Sink	

Coco Café

CITI-20	Front Hand Sink	Sink	
CITI-21	Water Dispenser	Dispenser	
CITI-22	Wash Sink	Sink	
CITI-23	Wash Sink	Sprayer	
CITI-24	Hand wash	Spiggot	
CITI-25	Hand Wash	Sprayer	not first pull
CITI-26	Bathroom	Sink	

Life Long Learning

CITI-27	Bathroom E	Sink	
CITI-28	Bathroom E Center	Sink	
CITI-29	Bathroom W Center	Sink	
CITI-30	Bathroom W	Sink	
CITI-31	Bottle Fill	Bottle Fill	

Dutch Ridge

CITI-32	Main Entrance BR L	Left	
CITI-33	Main Entrance BR L	Left Center	
CITI-34	Main Entrance BR L	Right Center	
CITI-35	Main Entrance BR L	Right	
CITI-36	Main Entrance BR R	Left	
CITI-37	Main Entrance BR R	Left Center	
CITI-38	Main Entrance BR R	Right Center	
CITI-39	Main Entrance BR R	Right	
CITI-40	Kitchen Sink L	Spiggot	
CITI-41	Kitchen Sink L	Sprayer	
CITI-42	Kitchen Sink R	Spiggot	
CITI-43	Kitchen Sink R	Sprayer	

SUNY Oswego

CITI-44	B14	Left Sink	
CITI-45	B14	Right Sink	
CITI-46	B15	Left Sink	not first pull
CITI-47	B15	Right Sink	not first pull
CITI-48	Hall Fountains	Drinking Fountain Tall	
CITI-49	Hall Fountains	Drinking Fountain Short	
CITI-50	Hall Fountains	Bottle Fill	

Building E415

CITI-50A	Room 5	Sink	
CITI-51	Northern Fountain	Tall fountain	
CITI-52	Northern Fountain	Short fountain	
CITI-53	Northern Fountain	Bottle Fill	
CITI-54	Room 4 Bathroom North	Sink	
CITI-55	Room 4 Bathroom South	Sink	
CITI-56	Southern Fountains	Left	
CITI-57	Southern Fountains	Left Center	
CITI-58	Southern Fountains	Left Bottle Fill	
CITI-59	Southern Fountains	Right Center	
CITI-60	Southern Fountains	Right	Leaking
CITI-61	Southern Fountains	Right Bottle Fill	
CITI-62	Room 8 Bathroom North	Sink	
CITI-63	Room 8 Bathroom South	Sink	
CITI-64	Room 9 Bathroom North	Sink	
CITI-65	Room 9 Bathroom South	Sink	
CITI-66	Room 12 Bathroom	Sink	
CITI-67	Room 13 Bathroom North	Sink	
CITI-68	Room 13 Bathroom South	Sink	

CITI-69	Staff Barthoom Hall BR	West Sink	
CITI-70	Staff Barthoom Hall BR	Center Sink	
CITI-71	Staff Barthoom Hall BR	East Sink	

Building W455

CITI-72	Room 4	Sink	
CITI-73	Room 4	Sprayer	
CITI-74	Fountians	North	
CITI-75	Fountians	North center	
CITI-76	Fountians	North Bottle Fill	
-	Fountians	South	Non Functional
-	Fountians	South Center	Non Functional
-	Fountians	South Bottle Fill	Non Functional
CITI-77	Hall Bathroom	West	
CITI-78	Hall Bathroom	Center	
CITI-79	Hall Bathroom	East	
CITI-80	Room 11	Sink	
CITI-81	Room 14	Sink	
CITI-82	Room 14 Bathroom	Sink	
CITI-83	Room 16	West	
CITI-84	Room 16	East	
CITI-85	Room 13	Sink	
CITI-86	Room 5	Sink	